

January 5, 2010

To: All Plan Holders

Re: **Addendum Number Two**

New Mexico Highlands University
Natatorium Renovations
Las Vegas, New Mexico

Project Number: 0920
RFP 897

From: Soleil West
11930 Menaul Blvd. NE, Suite 109
Albuquerque, New Mexico 87112
505-293-1477

This Addendum modifies the original Request for Proposal Documents dated November 23, 2009. Indicate receipt of this Addendum and the date on page one of the Contractor Representations and Certifications. There are **2 pages** to this Addendum, including this page.

Modifications to the Project Manual:

Product Prior Approvals: the following products have been approved for use on this project subject to detailed reviews during construction and subject to fulfilling LEED requirements. Physical size, performance, product construction, aesthetics, and ease of maintenance will be considered and does not necessarily encompass all considerations during review of any substituted product as being equal to the specified product.

Specification Section

10506 Box Lockers
Division 15

Approved Product

Republic
Rheem Hot Water Heater
Mifab Plumbing Specialties
Swanstone Service Sinks

Division 16 (Luminaries)

Type A
Type B/BE
Type C/CE
Type D
Type E
Type F/FE
Type G

Lithonia
Morlite
Morlite

Lithonia
Lithonia

Type H
Type K
Type L
Type M
Exit

Gotham
Lumark
Morlite
Lithonia

Modifications to the Drawings:

1. **Sheet E301:** Chem. 123: delete requirement of relocating Chlorinator Unit. Re-connect existing unit to new branch circuit indicated. Install new disconnect/Note 38 and connect as indicated.
2. **Sheet E102:** Mechanical 122/existing; delete Keyed Note 22, equipment to remain in place. Disconnect from existing circuit and re-connect to new circuit.
3. **Sheet E401:** Sound system, Keyed Notes 2, 3, 4 and 13, provide complete and operable wireless microphone system as manufactured by T.O.A. or an approved equal:
 - #WT-5810-Wireless Tuner with AC/DC adaptor
 - Two (2) #5320H Headset Microphone
 - Two (2) #5320A Aerobics Headset Microphone
 - #YW-4500 Wireless Antenna
 - #WD-4800 Antenna Distributor
 - #924MK2 Power Amplifier
 - Ceiling Speakers: #F-2852C in Pool
 - #F-2852C2 Exclusive of Pool

Provide speakers with manufacturer safety wire and non-ferrous speaker grilles.

Install all speakers in non-ferrous back boxes. The speakers in the Pool Area shall be installed in a non-ferrous enclosure that will be painted along with all conduit systems in exposed structure area.

Inter-connect all speakers with conduit system and extend to amplifier. Connect speakers with Belden #12 AWG Shielded Cable.

Inter-connect wireless tuner amplifier and antenna with shielded coaxial cable.

Install tuner and amplifier on wall rack in Office 106 with antenna installed on Pool side of wall outside office at 12'-0" above floor.

It is important that the contractor reference Keyed Note 4/Sheet E401 and that all equipment, raceways, etc., in Pool Area be rated for the environment.

end of Addendum No. Two.